MCY ENGINEERING, INC.
GLAZING CONSULTANT

12781 Miramar Pkwy. Ste. 301
Miramar, FL. 33027
P: 305 271-0117

PRODUCT APPROVAL EVALUATION REPORT

Product Manufacturer:	*Product Name/Model & Description:*
Trulite Glass and Aluminum Solutions, LLC. *403 Westpark Ct., Suite 201* *Pecahtree City, GA 30269*	***Series 351X Outswing Double Entrance Door*** *Outswing Aluminum Door – Large and Small Missile Impact*

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: 7th **Edition Florida Building Code (2020)/** 8th **Edition Florida Building Code (2023)**, inclusive of all Supplements effective as of this report date.

Compliance Method: 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer

Product Description: Product Approval **Drawing #AD16-33**, prepared by MCY Engineering, signed and sealed by Yiping Wang P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **inside and outside of the HVHZ** (High Velocity Hurricane Zone)
- Impact Resistance: **Large and Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
    - Maximum allowable wind loads at related maximum allowable size(s).
    - Other load limitations applicable to the product, if any.
    - Overall dimensions and material/grade of main product components, accessories, etc.
    - Illustrated diagrams of the attachment of the product to the structure.
    - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.

MCY ENGINEERING, INC.
GLAZING CONSULTANT

12781 Miramar Pkwy. Ste. 301
Miramar, FL. 33027
P: 305 271-0117

Test Reports:

Mandatory Tests (Tested in accordance with Florida Building Code Tests Protocols)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Fenestration Testing Lab (FTL) – Medley, FL	*FTL-8757, signed and sealed by Idalmis Ortega, P.E., FL #76905*	10/26/16	ASTM E283 (air infiltration) TAS 201 (large missile impact test) TAS 202 (uniform static test, forced entry test) TAS 203 (cyclic wind pressure loading) ASTM F842 (forced entry test)
Fenestration Testing Lab (FTL) – Medley, FL	*FTL-9378, signed and sealed by Idalmis Ortega, P.E., FL #76905*	5/19/17	ASTM E283 (air infiltration) TAS 201 (large missile impact test) TAS 202 (uniform static test, forced entry test) TAS 203 (cyclic wind pressure loading)
Excel Polymers, LLC. Burton, OH	*61787*	7/25/07	ASTM C 864 (EPDM rubber, seal gaskets, setting blocks, and spacers, 60 duro)
Excel Polymers, LLC. Burton, OH	*74326*	4/26/11	ASTM C 864 (EPDM rubber, seal gaskets, setting blocks, and spacers, 70 duro)

Engineering Analysis: The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- Rational analysis has been performed per Code requirements and acceptable standards of engineering principles (but not in lieu of standard tests required by the Code). No increase in allowable stress has been used in the evaluation of this product.

YIPING WANG
LICENSE
No 55983
STATE OF FLORIDA
PROFESSIONAL ENGINEER

August 01st, 2023