



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Product Evaluation Report

of

**Windsor Windows and Doors
Pinnacle Clad 2" LVL Mullion
(WZ3)(Impact)**

for

Florida Product Approval

FL# FL21905

Report No. 8334

Current Florida Building Code

Method: 2 – B (Engineering Evaluation)
Category: Windows
Sub – Category: Mullions

Product: Pinnacle Clad 2" LVL Mullion
Material: Glulam LVL
Product Dimensions: See Installation Instructions WWD002

Prepared for:


**Windsor Windows and Doors
900 S. 19th Street
West Des Moines, IA 50265**

Prepared by:

Hermes F. Norero, P.E.

Florida Professional Engineer # 73778

Date: 02/14/2023



Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2023.08.09 17:34:34 -04'00'

 954.399.8478

 954.744.4738

 BUILDINGDROPS.COM

 CONTACT@BUILDINGDROPS.COM

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Manufacturer: Windsor Windows and Doors

Product Category: Windows

Product Sub-Category: Mullions

Compliance Method: State Product Approval Method (2)(b)

Product Name: Pinnacle Clad 2" LVL Mullion
(WZ3) (Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Windsor Windows and Doors** based on Method 2b of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **WWD002**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and does not require an impact resistant covering in Wind Zones 3 or less.
4. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and does require an impact resistant covering in Wind Zones 4.
5. All configurations shown in installation instructions **WWD002** have been qualified as required by section 1709.8 of the current FBC.
6. Site conditions that deviate from the details of Installation Instructions **WWD002** require further engineering analysis by a licensed engineer or registered architect.
7. See Installation Instructions **WWD002** for size and design pressure limitations.

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Quality Assurance: The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Windows and Door Manufactures Association** (FBC Organization #: QUA2515).

Performance Standards: The product described herein has been tested per:

- AAMA/WDMA/CSA 101/I.S.2/A440-08/11
- AAMA 506-16
- ASTM E1886-13
- ASTM E1996-14

Referenced Code Sections: 1. 1709.8 of the current FBC

Referenced Data:

1. Product Testing performed by **Element Materials Technology**
Report: ESP020503P.Rev Dated: 09/29/2015
ESP020503P-Rev2.ASTM 11/04/2016
2. Quality Assurance Agency
Windows and Door Manufactures Association
(FBC Organization #: QUA2515)

Installation:

Refer to Installation Instructions (**WWD002**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**WWD002**) for allowable sizes and design pressures.

Conclusion:

All horizontal & vertical one-way & two-way clipped mullions evaluated meet the requirements for use as outlined by section 1709.8 of the current FBC.

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. The manufacturer has tested their products to the following test standard edition(s):

- 1) AAMA 506-11
- 2) ASTM E1886-02
- 3) ASTM E1996-02/05/06/09/12

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) AAMA 506-16
- 2) ASTM E1886-13
- 3) ASTM E1996-14

After review of the above mentioned referenced standards and editions, it has been found that no significant technical changes have been made to the test standards that would affect the results. All referenced standards have been found to be equivalent.