

PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
CHAMPION PTAC, LLC
4720 NW 15TH AVE. UNIT 4A
FORT LAUDERDALE, FL

PRODUCT
SERIES "HOTEL L-110"
HURRICANE IMPACT PTAC LOUVER SYSTEM
LARGE & SMALL MISSILE IMPACT

TEST REPORT # ATLSF 0908.01-16

MAX. UNIT SIZE: 96" X 24"
DESIGN PRESSURE: (MAX.) = - 110/+110 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS 201/ TAS202/TAS203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	REPORT DATE	ENGINEER
TAS202-94	UNIFORM STATIC AIR PRESSURE	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0908.01-16	10/24/2017	STEPHEN WARTER, P.E. PE #: 54395

SUPPLIMENTAL TESTS (TESTED IN ACCORDANCE WITH TAS 201 & TAS 203)

TAS 201-94 & TAS 203-94	LARGE MISSILE IMPACT & CYCLIC	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0908.01-16	10/24/2017	STEPHEN WARTER, P.E. PE #: 54395
----------------------------	-------------------------------------	----------------------------------	------------------	------------	-------------------------------------

UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT CONFORMS TO THE REQUIREMENTS OF THE 2020/ 2023 FLORIDA BUILDING CODE

PLEASE NOTE: TAS 201, 202 & 203 IS EQUIVELANT TO AAMA 501.

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316

STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION #32093
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431



Digitally signed by
Christopher Stanton
Date: 2024.01.26
16:49:02 -05'00'

