TURNER
ENGINEERING &
CONSULTING, INC.

2428 Old Natchez Trace Trail
Camden, TN 38320
Ph. 941-380-1574
FBPE C.O.A. #29779

Evaluation Report FPA-4764-PW-NI
September 30, 2020

Product Description: WinForce PVC Picture Window (Profiles 4764 with 4722 Adapter), Non-Impact

Manufacturer: Northeast Building Products, 4280 Aramingo Ave., Philadelphia, PA 19124

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 7th Edition (2020) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc. Trl., Camden, TN
2) Approval drawing FPA-4764-PW-NI, signed and sealed by Lucas A. Turner, P.E.
3) Test Reports 1380.02/04-106-11, and 1421.02/04-106-11, from Molimo, York, PA, TAS reports signed and sealed by Michael Stremmel, P.E., with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-11, TAS 202-94
4) Supplemental Calculations to support FPA-4764-PW-NI, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FPA-4764-PW-NI.

Limitations of Use: This product:

- May be used in the configurations and sizes as indicated in FPA-4764-PW-NI
- Achieves design pressures as shown in FPA-4764-PW-NI, with flange/equal leg frames
- Is non-impact and requires the use of shutters in windborne debris regions
- May be used in the High Velocity Hurricane Zone
- Requires glass as indicated in note 5, sheet 1, of FPA-4764-PW-NI
- Requires Deceuninck white rigid PVC extrusions per NOA 19-0619.03. I have evaluated the framing material in this NOA and find that it complies with the requirements of the 7th Ed. (2020) Florida Building Code for use in this product.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Northeast Building Products or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.

Lucas Turner
2020.10.01
11:00:45
-05'00'

LUCAS A. TURNER
LICENSE
No. 58201
STATE OF
FLORIDA
PROFESSIONAL ENGINEER

9/30/2020
Lucas A. Turner, P.E.
FL PE #58201