

**Evaluation Report FPA-Panorama-SGD-NI**  
September 30, 2020

**Product Description:** Panorama PVC Sliding Glass Doors and Sidelites, Non-Impact

**Manufacturer:** Northeast Building Products, 4280 Aramingo Ave., Philadelphia, PA 19124

**Statement of Compliance:** This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 7<sup>th</sup> Edition (2020) Florida Building Code for use outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

**Technical Documentation:**

- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing FPA-Panorama-SGD-NI, signed and sealed by Lucas A. Turner, P.E.
- 3) Test reports C7941 03-501-44-r0, C8717 02-501-44-r0, D0979 03-501-44-r1, and D1113 02-501-44-r0, from Intertek/ATI, Springdale, PA, with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-11
- 4) Supplemental Calculations to support FPA-Panorama-SGD-NI, signed and sealed by Lucas A. Turner, P.E.


**Installation:** Units must be installed according to approval document FPA-Panorama-SGD-NI.

**Limitations of Use:** This product:

- May be used in the configurations, sizes, and design pressures as indicated in FPA-Panorama-SGD-NI
- Is non-impact resistant and requires the use of shutters in windborne debris locations
- May not be used in the High Velocity Hurricane Zone
- Requires glass as indicated in note 5, sheet 1, of FPA-Panorama-SGD-NI
- Requires Chelsea Building Products rigid PVC extrusions with current listing as AAMA 303 Certified Profile Licensee

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Northeast Building Products or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.

Lucas Turner  
2020.10.01  
10:59:01  
-05'00'



*LT*  
9/30/2020  
Lucas A. Turner, P.E.  
FL PE #58201