

W. W. Schaefer Engineering & Consulting, P.A. (CA #6809)

7480 150th Court North
Palm Beach Gardens, FL 33418
Phone (561)744-3424

ENGINEER'S EVALUATION REPORT #WWS-336

Prepared for:

Palm City Millwork, Inc.
3313 SW 42nd Ave.
Palm City, FL 34990
Phone: 800-273-5598

Prepared by:

Warren W. Schaefer, P.E.
Florida Professional Engineer #44135

Manufacturer: Palm City Millwork, Inc.

Product Category: Windows

Evaluation Method: 1-D (Engineer's evaluation)

Product model & name: Wood Impact Out-Swing Vent & Fixed Casement Windows

Documents that must accompany this report:

1. W. W. Schaefer Engineering & Consulting drawing No. 1931

Window size restrictions and assembly requirements:

See drawing No. 1931

Maximum allowable design pressure:

+/-70 psf

Installation requirements:

See drawing No. 1931

Code compliance:

Code section(s) considered with this evaluation:

FBC Chapter 17

Wood Coatings:

All wood members shall be of an approved durable species or be treated in an approved method with an approved preservative per applicable codes and standards

Glass:

All glass meets the current ASTM E1300 standard.

Mullions:

Mullion conditions stated in this approval have been tested in accordance with TAS-201, 202 & 203 and meet the requirements of FBC.

Test Standards applicable to the testing of these windows:
TAS-201, 202 & 203

Test Laboratory: Blackwater Testing, Inc.

Test report numbers: BT-PCM-16-001

Note: All HVHZ test reports have been signed & sealed by a Florida PE.

General report notes & system limitations:

1. All size & installation conditions shown in this report and the referenced drawing No. 1931 are based off the referenced test reports and/or engineering analysis in accordance with the Florida Building Code.
2. Windows shall be constructed in accordance with the descriptions in this report, and the manufacturer's state approved quality assurance entity specifications.
3. This product is approved for use in & outside of the High Velocity Hurricane Zones (HVHZ).
4. Job required design wind pressure shall be calculated in accordance with the Florida Building Code Chapter 16 and ASCE 7 Minimum Design Loads for Buildings and Other Structures (0.85 directionality factor may apply per the current ASCE 7 standard).
5. These windows are both small & large missile impact rated for use in wind zone 4 & missile level "D" locations and need not be shuttered.
6. When applicable, all safety glass requirements must be met per FBC chapter 24.

Quality Assurance Entity: Architectural Testing, Inc (ATI)

MAR 02 2018

Warren W. Schaefer, P.E.
Florida P.E. #44135

