



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 22555

Date: 09/01/2023

Detailed Product Description:

Manufacturer: TERRACORE PANELS, LLC.

Manufacturer Address: 2030 IRVING BLVD DALLAS, TX 75207

Model Name: STONE VENEER HONEYCOMB PANELS BY ALLCOMB

Maximum Load: +100 PSF, -100 PSF (Large Missile Impact)

Installation Drawings # 17-14

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS-02)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Architectural Testing, Inc.	4/26/2017	G0518.01-801-44	Tyler Westerling, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Architectural Testing, Inc.	4/26/2017	G0518.01-801-44	Tyler Westerling, P.E.
ASTM E330	Uniform Static Air Press.	Architectural Testing, Inc.	4/26/2017	G0518.01-801-44	Tyler Westerling, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 (TAS 201 & 203) ASTM E1886/1996	Large Missile Impact & Cyclic	Architectural Testing, Inc.	4/26/2017	G0518.01-801-44	Tyler Westerling, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 9/1/2023