R W B C

R W Building Consultants, Inc.
Consulting and Engineering Services for the Building Industry
P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197
Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.: ***FL-23505.4***
Date: ***July 5, 2023***

Product Category	Sub Category	Manufacturer	Product Name
Windows	**Double Hung**	**Soft-Lite LLC** **10250 Philipp Parkway** **Streetsboro, OH 44241** **(330) 528-3400**	**"Barcelona"** **Model "SH30P"** **Single Hung Window** **"Non-Impact"**

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Soft-Lite LLC., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone".
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product must be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-23505.4 require further engineering analysis by a licensed engineer or registered architect.
8. See drawing FL-23505.4 for size and design pressure limitations.

Supporting Documents:

1.

Test Report No.	**Test Standard**	**Testing Laboratory**	**Signed by**
T201-17	AAMA/WDMA/CSA 101/I.S.2/A440-11	Farabaugh Testing Inc.	Paul G. Farabaugh
T183-17	AAMA/WDMA/CSA 101/I.S.2/A440-11	Farabaugh Testing Inc.	Paul Medwig
T184-17	AAMA/WDMA/CSA 101/I.S.2/A440-11	Farabaugh Testing Inc.	Paul Medwig
T177-18	AAMA/WDMA/CSA 101/I.S.2/A440-11	Farabaugh Testing Inc.	Paul G. Farabaugh

2.

Drawing No.	**Prepared by**	**Signed & Sealed by**
No. FL-23505.4	RW Building Consultants, Inc. (#9813)	Lyndon F. Schmidt, P.E.

3.

Calculations	**Prepared by**	**Signed & Sealed by**
Buck Anchoring	RW Building Consultants, Inc. (#9813)	Lyndon F. Schmidt, P.E.

4. **Quality Assurance**
Certificate of Participation issued by Farabaugh Engineering and Testing, Inc., certifying that Soft-Lite LLC is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.

Digitally signed by Lyndon F Schmidt
Date: 2023.07.05 12:58:40 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by **L. F. Schmidt** on **7-5-23**.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA