

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514099A

Manufacturer: All American Window Company, LLC
PO Box 80039
Charleston, SC 29416

Product Line: 1950 SL Single Slider Window 71" x 56" Non-impact

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03178 revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: B8184.01-109-47 signed by Timothy J. McGill.
Architectural Testing, York PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design Pressure: ± 25.06 psf
Water penetration resistance: 3.76psf
3. Test report No.: D7803.01-109-44 signed and sealed by Michael D. Stremmel P.E.
Architectural Testing, York PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design Pressure: ± 25.06 psf
Water penetration resistance: 7.52psf
4. Anchor calculations, report number 514097-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.
5. Comparative analysis, report number 514097-2, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to approval drawing.
- Unit size: Refer to approval drawing.
- Approved configurations: OX and XO
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-03178, revision A.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

