



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 East Dania Beach Blvd.

Suite 338

Dania Beach, FL 33004

954.399.8478 PH

954.744.4738 FX

contact@buildingdrops.com

Product Evaluation Report

of

**Andersen Corporation
Aluminum Clad Wood Hinged
Inswing Entry Door
(NON-HVHZ) (NON-IMPACT)**

for

Florida Product Approval

FL# FL24175

Report No. 6712

Current Florida Building Code

Method: 1 – D (Engineering Evaluation)
Category: Exterior Doors
Sub – Category: Swinging Exterior Door Assemblies

Product: Aluminum Clad Wood Hinged
Inswing Entry Door
(NON-HVHZ) (NON-IMPACT)

Material: Finger Jointed Wood & LVL

Product Dimensions: See Installation Instructions, AWD149

Prepared for:

**Andersen Corporation
100 Fourth Ave North
Bayport, MN 55003-1096**

Prepared by:

Hermes F. Norero, P.E.


Florida Professional Engineer # 73778

Date: 09/07/2020

Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F Norero
Reason: I am approving this document
Date: 2020.10.15 09:06:00 +02'00'



Hermes F. Norero, P.E.

Florida P.E. No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL24175

Date: 09/07/20

Report No: 6712

Manufacturer: Andersen Corporation.

Product Category: Exterior Doors

Product Sub-Category: Swinging Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: Aluminum Clad Wood Hinged Inswing Entry Door
(NON-HVHZ) (NON-IMPACT)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Andersen Windows, Inc.** based on Method 1d of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **AWD149**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does** require an impact resistant covering.
5. Site conditions that deviate from the details of Installation Instructions **AWD149** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **AWD149** for size and design pressure limitations.



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL24175

Date: 09/07/20

Report No: 6712

Quality Assurance Entity: The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Window and Door Manufacturers Association** (FBC Organization #: QUA2515).

Performance Standards: The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101.I.S.2/A440-11
- AAMA 450-10

Referenced Data: 1. Product Testing performed by **Architectural Testing, Inc.** (FBC Organization #: TST1795)

Report #: A5322.01-201-44,	Report Date: 03/23/11
Report #: A5323.01-201-44,	Report Date: 03/23/11
Report #: A5324.01-201-44,	Report Date: 03/22/11
Report #: A5325.01-201-44,	Report Date: 03/23/11
Report #: A5326.01-201-44,	Report Date: 03/23/11
Report #: A5327.01-201-44,	Report Date: 03/23/11
Report #: A5328.01-201-44,	Report Date: 03/25/11
Report #: A5329.01-201-44,	Report Date: 03/25/11
Report #: A7233.01-201-44,	Report Date: 05/20/11
Report #: A5330.01-201-44,	Report Date: 03/25/11
Report #: A4097.01-201-44,	Report Date: 10/15/10
Report #: A4097.02-201-44,	Report Date: 10/15/10
Report #: A4097.03-201-44,	Report Date: 10/15/10
Report #: A4097.04-201-44,	Report Date: 12/29/10
Report #: A4097.05-201-44,	Report Date: 12/29/10
Report #: A4098.01-201-44,	Report Date: 12/30/10
Report #: A4098.02-201-44,	Report Date: 12/30/10
Report #: A4098.03-201-44,	Report Date: 12/30/10
Report #: A4098.04-201-44,	Report Date: 12/30/10
Report #: A4098.05-201-44,	Report Date: 12/30/10
Report #: A4102.01-201-44,	Report Date: 01/04/11
Report #: A4102.02-201-44,	Report Date: 01/04/11
Report #: A4102.03-201-44,	Report Date: 01/04/11
Report #: A4102.04-201-44,	Report Date: 01/04/11
Report #: A4105.01-201-44,	Report Date: 01/04/11
Report #: A4105.02-201-44,	Report Date: 01/04/11
Report #: A4106.01-201-44,	Report Date: 01/04/11
Report #: A4106.02-201-44,	Report Date: 01/04/11
Report #: A7325.01-201-44,	Report Date: 05/12/11
Report #: E7353.01-201-47	Report Date: 05/04/15

Hermes F. Norero, P.E.

Florida P.E. No. 73778

Page 3 of 4



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL24175

Date: 09/07/20

Report No: 6712

Report #: E7354.01-201-47	Report Date: 06/22/15
Report #: E7355.01-201-47	Report Date: 05/04/15
Report #: E7356.01-201-47	Report Date: 05/04/15
Report #: E7357.01-201-47	Report Date: 06/22/15
Report #: E7358.01-201-47	Report Date: 04/20/15
Report #: E7359.01-201-47	Report Date: 05/04/15
Report #: E7361.01-201-47	Report Date: 04/20/15
Report #: E7364.01-201-47	Report Date: 04/22/15
Report #: I4405.01-201-47	Report Date: 09/06/18

2. Quality Assurance Entity
Window and Door Manufacturers Association
(FBC Organization #QUA2515)

Installation Method: Please refer to installation instructions, **AWD149**, for anchor methods, selection, spacing, edge distances, embedment's and further details of installation.

Design Pressure: Please refer to installation instructions, **AWD149**, for mull combination grouping, configurations, and corresponding design pressures.

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. Andersen Corporation has tested their products to the following test standard edition(s):

- 1) AAMA/WDMA/CSA 101/I.S.2/A440-08
- 2) AAMA 450-06

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) AAMA/WDMA/CSA 101/I.S.2/A440-11
- 2) AAMA 450-10

After review of the above mentioned referenced standards and editions, it has been found that the results and tests carried out meet the requirements for compliance. All referenced standards have been found to be equivalent.

Hermes F. Norero, P.E.
Florida P.E. No. 73778
Page 4 of 4