

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514057

Manufacturer: Trespa North America, Ltd.
62 Greene Street, Grd Flr
New York, NY 10012

Product Line: Trespa Pura NFC Flush and Lap Siding

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03146, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: G9793.01-109-18 signed and sealed by Joseph A. Reed P.E.
Architectural Testing Inc., York, PA
TAS 201-94 Small Missile Impact Test, Level A, Wind Zone 4
TAS 202 -94 Uniform Static Air Pressure, ± 80.0 psf design pressure.
TAS 203-94 Cyclic Pressure loading ± 80.0 psf design pressure
3. Report No.: G9795.01-109-18 signed and sealed by Joseph A. Reed P.E.
Architectural Testing Inc., York, PA
TAS 201-94 Small Missile Impact Test, Level A, Wind Zone 4
TAS 202 -94 Uniform Static Air Pressure, ± 80.0 psf design pressure.
TAS 203-94 Cyclic Pressure loading ± 80.0 psf design pressure
4. Anchor calculations, report number 514057-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 80.0 psf
- Siding panel size: 7 3/16" x 120" Flush
7 3/8" x 120" Lap
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions, when installed at 30 ft. or higher above ground level.
- Siding may be installed horizontally or vertically.
- Siding material to be High Pressure Phenolic Resin Laminate.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03146.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

