

Engineering Evaluation Report # 4090-121621

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Florida Registration: #29296

Manufacturer:

CGI Windows and Doors
3780 W 104th St.
Hialeah, FL 33018

Product Description:

CD4090A Side Hinged Door, FL-24447

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

This product has been evaluated and is in compliance with the current Florida Building Code. This product is not for use in the "High Velocity Hurricane Zone" (HVHZ). This product is not Impact Resistant and requires shutters in windborne debris regions.


Supporting Technical Documentation:

1. Approval document: drawing number CD4090FPA Rev. A1, signed and sealed by A. Lynn Miller, P.E.

2. Test Report(s) No. FTL-6631, FTL-6632, FTL-6633, FTL-6634, FTL-6635, FTL-6644, FTL-6645, FTL-6646, FTL-6681 & 20-2108.1-5 Fenestration Testing Laboratories, Medley, FL 33166
AAMA/WDMA/CSA 101/IS2/A440 2008

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and does require impact protection in wind borne debris regions.
- Frame and panel material to be extruded aluminum.
- Units must be installed in accordance with approval documents.



A. Lynn Miller, P.E.
P.E. # 58705