

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 25673

Date: 12/14/2018

Detailed Product Description:

Manufacturer: FAOUR GLASS TECHNOLOGIES

Manufacturer Address: 5119 W KNOX STREET, TAMPA, FLORIDA 33634

Model Name: SERIES 'SLIMPACT' XL SSG GLASS WALL SYSTEM(HVHZ)

Maximum D.L.O. Width: 240"

Maximum D.L.O. Height: 144"

Maximum Load: +110 PSF,-110 PSF(Large Missile Impact)

Installation Drawings # W18-27

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

The above maximum parameters do not occur simultaneously.
See charts on installation drawings for combinations of span vs. load.

Comparative analysis used Yes No

Mandatory Tests (Tested in accordance with AAMA 501/101/I.S.2/NAFS/TAS 202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	Intertek	12/05/2017	H6731.01-401-18-RO	Gary T Hartman, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Intertek	12/05/2017	H6731.01-401-18-RO	Gary T Hartman, P.E.
ASTM E330 & TAS 202	Uniform Static Air Pressure	Intertek	12/05/2017	H6731.01-401-18-RO	Gary T Hartman, P.E.


Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Intertek	12/05/2017	H6731.01-401-18-RO	Gary T Hartman, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2017 Florida Building Code.

Evaluation Report Engineer:

Javad Ahmad PE # 70592
Al-Farooq Corporation EB # 3538



Sealed 12/17/18