

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 25678

Date: 12/18/2017

Detailed Product Description:

Manufacturer: EXCLUSIVE WOOD DOORS

Manufacturer Address: 195 NW 70 AVE – MIAMI, FL. 33126

Model Name: GLAZED INSWING DOOR WITH SIDELITES (L.M.I)

Maximum Frame Width: 37-3/4"(X), 74-1/2" (XX), 25-1/2"(O), 127"(OXXO)

Maximum Frame Height: 98-1/4"(X, XX), 98" (O)

Maximum Load: +47 PSF, -47 PSF (Large Missile Impact)

Installation Drawings # W17-113

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

Comparative analysis used ☐ Yes ☒ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Certified Testing Laboratories	06/01/2010	CTLA-2027W	Ramesh Patel, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Certified Testing Laboratories	06/01/2010	CTLA-2027W	Ramesh Patel, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Certified Testing Laboratories	04/30/2002 06/01/2010	CTLA-836W2 CTLA-2027W	Ramesh Patel, P.E.
AAMA 1304	Forced Entry Test	Certified Testing Laboratories	06/01/2010	CTLA-2027W	Ramesh Patel, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)


TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Certified Testing Laboratories	04/30/2002 06/01/2010	CTLA-836W2 CTLA-2027W	Ramesh Patel, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2017 Florida Building Code.

Evaluation Report Engineer:

Javad Ahmad
Al-Farooq Corporation

PE # 70592
EB # 3538



Sealed: 12/18/2017