

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 25678

Date: 12/18/2017

Detailed Product Description:

Manufacturer: EXCLUSIVE WOOD DOORS

Manufacturer Address: 195 NW 70 AVE – MIAMI, FL. 33126

Model Name: OPAQUE OUTSWING DOOR WITH SIDELITES (N.I.)

Maximum Frame Width: 37-3/4"(X), 74-1/2" (XX), 25-1/2"(O), 127"(OXXO)

Maximum Frame Height: 97-1/16"(X, XX), 96-13/16" (O)

Maximum Load: +47 PSF, -47 PSF (Non Impact)

Installation Drawings # W17-116

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

Comparative analysis used ☐ Yes ☒ No


Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Certified Testing Laboratories	06/01/2010 04/30/2002 03/08/2002	CTLA-2027W CTLA-836W2 CTLA-836W1	Ramesh Patel, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Certified Testing Laboratories	06/01/2010 04/30/2002	CTLA-2027W CTLA-836W2	Ramesh Patel, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Certified Testing Laboratories	06/01/2010 04/30/2002 04/30/2002 03/08/2002	CTLA-2027W CTLA-836W1 CTLA-836W2 CTLA-836W	Ramesh Patel, P.E.
AAMA 1304	Forced Entry Test	Certified Testing Laboratories	06/01/2010 04/30/2002 04/30/2002 03/08/2002	CTLA-2027W CTLA-836W CTLA-836W2 CTLA-836W1	Ramesh Patel, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2017 Florida Building Code.

Evaluation Report Engineer:

Javad Ahmad PE # 70592
Al-Farooq Corporation EB # 3538



Sealed: 12/18/2017