



# AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

## PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

### Detailed Product Description:

**Manufacturer:** EXCLUSIVE WOOD DOORS

**Manufacturer Address:** 1950 NW 70 AVE – MIAMI, FL. 33126

**Model Name:** OPAQUE INSWING DOOR WITH SIDELITES

**Maximum Load:** +47 PSF, -47 PSF (Non Impact)

**Installation Drawings #** W17-115

**FL 25678**

**Date:** 08/18/2026

| This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.                                                                                                |                           |                                |                                                                                      |                                                     |                    |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|--------------------------------|--------------------------------------------------------------------------------------|-----------------------------------------------------|--------------------|
| For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.                                                                                         |                           |                                |                                                                                      |                                                     |                    |
| Comparative analysis used ____ Yes ____ <u>X</u> No                                                                                                                                     |                           |                                |                                                                                      |                                                     |                    |
| <b>Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)</b>                                                                                                          |                           |                                |                                                                                      |                                                     |                    |
| TEST                                                                                                                                                                                    | DESCRIPTION               | TEST LOCATION                  | TEST REPORT DATE                                                                     | TEST REPORT #                                       | Test Sealed by     |
| ASTM E283                                                                                                                                                                               | Air Infiltration Leakage  | Certified Testing Laboratories | 03/08/2002<br>06/01/2010                                                             | CTLA-836W1<br>CTLA-2027W                            | Ramesh Patel, P.E. |
| ASTM E331<br>OR ASTM 547 &<br>TAS 202                                                                                                                                                   | Water Penetration         | Certified Testing Laboratories | 06/01/2010                                                                           | CTLA-2027W                                          | Ramesh Patel, P.E. |
| ASTM E330<br>& TAS 202                                                                                                                                                                  | Uniform Static Air Press. | Certified Testing Laboratories | 04/31/2002<br>04/31/2002<br>03/08/2002<br>06/01/2010                                 | CTLA-836W1<br>CTLA-836W2<br>CTLA-836W<br>CTLA-2027W | Ramesh Patel, P.E. |
| AAMA 1304                                                                                                                                                                               | Forced Entry Test         | Certified Testing Laboratories | 04/31/2002<br>03/08/2002<br>06/01/2010                                               | CTLA-836W<br>CTLA-836W1<br>CTLA-2027W               | Ramesh Patel, P.E. |
| Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code. |                           |                                |                                                                                      |                                                     |                    |
| <b>Evaluation Report Engineer:</b>                                                                                                                                                      |                           |                                |  |                                                     |                    |
| Jalal Farooq<br>Al-Farooq Corporation                                                                                                                                                   |                           |                                |                                                                                      |                                                     |                    |
| PE # 81223<br>EB # 3538                                                                                                                                                                 |                           |                                | Sealed: 9/1/2026                                                                     |                                                     |                    |