

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: CERAMITEX 6mm+ WALL PANEL

MANUFACTURER: ELEMEX
530 ADMIRAL DRIVE
LONDON, ONTARIO N5V OB2

To all concerned,

The Ceramitex 6mm+ Wall Panel System, manufactured by Elemex, is a sintered compact surface veneer manufactured with fiberglass reinforced mesh backing adhered to an aluminum frame. The system has been tested per TAS 202 and TAS 203 by Intertek-ATI, with results shown in test report 102676238TOR-004.

Technical Documentation:

1. Drawing "Ceramitex 6mm+ Wall Panel" dated 7/21/23 (Rev), signed and sealed by Scott Wolters, PE.
2. Test report listed above by Intertek-ATI, Inc. signed and sealed by Gary Hartman, PE.
3. Supplemental Calculations to support "Ceramitex 6mm+ Wall Panel" drawing, signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 8th Edition (2023) Florida Building Code generally, and chapters 14,16, and 20 specifically, including the HVHZ provisions.


Limitations: This Wall Panel System is approved for use inside and outside of the HVHZ. This system is not approved for impact resistance as a stand-alone product. In the HVHZ or windborne debris regions, it may only be installed over impact resistant substrates meeting the requirements of FBC Section 1626.


<u>Overall Dimensions:</u>	Maximum Panel Width:	120"
	Maximum Panel Height:	60"
	Maximum Design Pressure:	+/- 66.6 psf

The system is further limited as noted in drawing "Ceramitex 6mm+ Wall Panel"

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
JUN 25 2024



SPECIALIZING IN MIAMI-DADE AND FLORIDA PRODUCT APPROVALS FOR ROOFING & GLAZING PRODUCTS