



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 26343

Date: 07/11/2023

Detailed Product Description:

Manufacturer: E.S. WINDOWS, LLC.


Manufacturer Address: 3550 N.W. 49 STREET – MIAMI, FL. 33142

Model Name: SERIES 4000 ALUMINUM SLIDING GLASS DOOR

Maximum Load: +90 PSF/-103 PSF (Large Missile Impact)

Installation Drawings # 18-11F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used ☒ Yes ☐ No					
Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	Fenestration Testing Lab, Inc.	10/09/2003	FTL-3908	Joseph Chan, P.E.
			09/26/2003	FTL-3909	Joseph Chan, P.E.
			09/30/2003	FTL-3910	Joseph Chan, P.E.
			09/22/2004	FTL-4287	Edmundo Largaespada, P.E.
		Blackwater Testing, Inc.	02/20/2015	FTL-7894	Idalmis Ortega, P.E.
			04/18/2016	BTW-ESW-15-004	Yamil G. Kuri, P.E.
			12/12/2017	BTW-ESW-17-017	Constantin Bortes, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Fenestration Testing Lab, Inc.	10/09/2003	FTL-3908	Joseph Chan, P.E.
			09/26/2003	FTL-3909	Joseph Chan, P.E.
			09/30/2003	FTL-3910	Joseph Chan, P.E.
			09/22/2004	FTL-4287	Edmundo Largaespada, P.E.
		Blackwater Testing, Inc.	02/20/2015	FTL-7894	Idalmis Ortega, P.E.
			04/18/2016	BTW-ESW-15-004	Yamil G. Kuri, P.E.
			11/16/2017	BTW-ESW-17-017	Constantin Bortes, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Lab, Inc.	10/09/2003	FTL-3908	Joseph Chan, P.E.
			09/26/2003	FTL-3909	Joseph Chan, P.E.
			09/30/2003	FTL-3910	Joseph Chan, P.E.
			09/22/2004	FTL-4287	Edmundo Largaespada, P.E.
		Blackwater Testing, Inc.	02/20/2015	FTL-7894	Idalmis Ortega, P.E.
			04/18/2016	BTW-ESW-15-004	Yamil G. Kuri, P.E.
			11/16/2017	BTW-ESW-17-017	Constantin Bortes, P.E.
ASTM F842	Forced Entry Test	Fenestration Testing Lab, Inc.	10/09/2003	FTL-3908	Joseph Chan, P.E.
			09/26/2003	FTL-3909	Joseph Chan, P.E.
			09/30/2003	FTL-3910	Joseph Chan, P.E.
			09/22/2004	FTL-4287	Edmundo Largaespada, P.E.
		Blackwater Testing, Inc.	02/20/2015	FTL-7894	Idalmis Ortega, P.E.
			04/18/2016	BTW-ESW-15-004	Yamil G. Kuri, P.E.
			11/16/2017	BTW-ESW-17-017	Constantin Bortes, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 (TAS 201 & 203) ASTM E1886/E1996 ANSI Z97.1	Large Missile Impact & Cyclic	Fenestration Testing Lab, Inc. Blackwater Testing, Inc.	10/09/2003 09/26/2003 09/30/2003 09/22/2004 01/24/2008 02/20/2015 04/18/2016 11/16/2017	FTL-3908 FTL-3909 FTL-3910 FTL-4287 FTL-5471 FTL-7894 BTW-ESW-15-004 BTW-ESW-17-017	Joseph Chan, P.E. Joseph Chan, P.E. Joseph Chan, P.E. Edmundo Largaespada, P.E. Idalmis Ortega, P.E. Idalmis Ortega, P.E. Yamil G. Kuri, P.E. Constantin Bortes, P.E.
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.					
Evaluation Report Engineer: Jalal Farooq Al-Farooq Corporation			 Sealed: 7/12/2023		
PE # 81223 EB # 3538					