

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 26359

Date: 08/26/2026

Detailed Product Description:

Manufacturer: E.S. WINDOWS, LLC.

Manufacturer Address: 3550 N.W. 49 STREET – MIAMI, FL. 33142

Model Name: SERIES “ES-P252” THERMAL ALUMINUM FIXED WINDOW

Maximum Load: +110 PSF, -150 PSF (Large Missile Impact)

Installation Drawings # 18-30F


This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ☒ Yes ☐ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Blackwater Testing Inc. Fenestration Testing Laboratory, Inc	12/05/2017 12/14/2018 02/05/2021 04/06/2021	BT-ESW-17-022 BT-ESW-17-022B FTL-12278 FTL-12502	Constantin Bortes, PE Idalmis Ortega, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Blackwater Testing Inc. Fenestration Testing Laboratory, Inc	12/05/2017 12/14/2018 02/05/2021 04/06/2021	BT-ESW-17-022 BT-ESW-17-022B FTL-12278 FTL-12502	Constantin Bortes, PE Idalmis Ortega, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Blackwater Testing Inc. Fenestration Testing Laboratory, Inc	12/05/2017 12/14/2018 02/05/2021 04/06/2021	BT-ESW-17-022 BT-ESW-17-022B FTL-12278 FTL-12502	Constantin Bortes, PE Idalmis Ortega, P.E.
ASTM F588	Forced Entry	Fenestration Testing Laboratory, Inc	04/06/2021	FTL-12502	Idalmis Ortega, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 TAS 201 & 203 ASTM 1886/1996 ANSI Z97.1	Large Missile Impact & Cyclic	Blackwater Testing Inc. Fenestration Testing Laboratory, Inc	12/05/2017 12/14/2018 02/05/2021 04/06/2021	BT-ESW-17-022 BT-ESW-17-022B FTL-12278 FTL-12502	Constantin Bortes, PE Idalmis Ortega, P.E.
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.					
Evaluation Report Engineer: Jalal Farooq Al-Farooq Corporation			 Sealed: 8/26/2026		
PE # 81223 EB # 3538					