

Product Evaluation Report**Report No.:** FL-26908.11**Date:** February 16, 2021

Product Category	Sub Category	Manufacturer	Product Name
Windows	Fixed	Sunrise Windows, LTD. 200 Enterprise Drive Temperance, MI 48182 (734) 847-8778	"Restorations" Series Standard Picture Window "Non-Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Sunrise Windows, LTD., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Dept. of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 7th Edition (2020) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection, this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-26908.11 require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-26908.11 for size and design pressure limitations.

Supporting Documents:

- | | |
|---|--|
| 1. Test Report No.
TEL 15502481
TEL 15502482 | Test Standard
AAMA/WDMA/CSA 101 I.S.2/A440-11
AAMA/WDMA/CSA 101 I.S.2/A440-11 |
|---|--|

Testing Laboratory
Testing Evaluation Labs
Testing Evaluation Labs

Signed by
V.K. Wright
V.K. Wright


- | | |
|--|---|
| 2. Drawing No.
No. FL-26908.11 | Prepared by
RW Building Consultants, Inc. (#9813) |
|--|---|

Signed & Sealed by
Lyndon F. Schmidt, P.E.

- | | |
|-------------------------------------|---|
| 3. Calculations
Anchoring | Prepared by
RW Building Consultants, Inc. (#9813) |
|-------------------------------------|---|

Signed & Sealed by
Lyndon F. Schmidt, P.E.

4. **Quality Assurance**
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Sunrise Windows, LTD. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.



Lyndon F. Schmidt, P.E.
FL PE No. 43409
2/16/2021