

**Product Evaluation Report** **Report No.:** FL-26909.2  
**Date:** April 19, 2018

Product Category	Sub Category	Manufacturer	Product Name
Windows	Horizontal Slider	Sunrise Windows, LTD. 200 Enterprise Drive Temperance, MI 48182 (734) 847-8778	Series 7230 Coastal Performance Horizontal Sliding Window "Impact"

**Scope:** Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Sunrise Windows, LTD., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Dept. of Business & Professional Regulation.


RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

**Limitations:**

- This product has been evaluated and is in compliance with the 6th Edition (2017) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in areas requiring wind borne debris protection, this product is complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 3 as definded in ASTM E1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-26909.2 require further engineering analysis by a licensed engineer or registered architect.
- See drawing FL-26909.2 for size and design pressure limitations.

**Supporting Documents:**

- |  |   |   |  |
|--|---|---|--|
| 1. <b>Test Report No.</b><br>ATI G8725.04-501-44<br>ATI G8725.03-501-44  | <b>Test Standard</b><br>AAMA/WDMA/CSA 101 I.S.2/A440-11<br>ASTM E1886-05 / E1996-05 | <b>Testing Laboratory</b><br>Architectural Testing<br>Architectural Testing | <b>Signed by</b><br>Joseph E. Allison<br>Joseph E. Allison |
| 2. <b>Dade County NOA</b><br>17-0712.05  | <b>Materials</b><br>Saflex PVB Interlayer (Eastman Chemical)                        |   |  |
| 3. <b>Drawing No.</b><br>No. FL-26909.2  | <b>Prepared by</b><br>RW Building Consultants, Inc. (CA #9813)                      |   | <b>Signed &amp; Sealed by</b><br>Lyndon F. Schmidt, P.E.   |
| 4. <b>Calculations</b><br>Anchoring  | <b>Prepared by</b><br>RW Building Consultants, Inc. (CA #9813)                      |   | <b>Signed &amp; Sealed by</b><br>Lyndon F. Schmidt, P.E.   |
| 5. <b>Quality Assurance</b><br>Certificate of Participation issued by National Accreditation and Management Institute, certifying that Sunrise Windows, LTD. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. |   |   |  |



Lyndon F. Schmidt, P.E.  
FL PE No. 43409  
4/19/2018