

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514178

Manufacturer: All Seasons Commercial
1293 North Harvey Mitchell Parkway
Bryan, TX 77803

Product Line: Series 3250 Aluminum Single Hung Window 60" x 99" Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03225, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: CCLI 17-164 signed by Wesley Wilson.
Construction Consulting Laboratory, Carrollton, TX
AAMA/WDMA/CSA 101/I.S.2/A440-08
Design pressure: ± 75.19 psf
Water penetration resistance 12.11psf
3. Anchor calculations, report number 514178-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 75.0 psf
- Unit size: 60" x 99"
- Units must be glazed per ASTM E1300-04/09.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and does require impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T5

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03225.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

