R W B C

R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.: ***FL-27194.6***

Date: ***June 19, 2025***

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Exterior Doors Components	Qingdao Sea Nova Building Profiles Products Co., LTD Songjia Yanghe Town Jiaohou Dist. Qingdao City China, NON-US 266425	"Pro-Tek" Series Composite Thresholds w/ Aluminum Deck Inswing "Non-Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Qingdao Sea Nova Building Profiles Products Co., LTD, based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Dept. of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection, this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. These "NON-IMPACT" door thresholds, as components, are to be used as a substitute for similar components in a non-impact approved door system possessing a current Florida Statewide Product Approval.
5. The design pressure of the assembly shall be the lesser of the design pressure for the component assembly shown in this approval or the design pressure of the system assembly used in conjunction with this approval.
6. The maximum frame size of the door assembly shall be the lesser of the maximum frame size stated in this approval or the maximum frame size of the system assembly approval used in conjunction with this approval.
7. Site conditions that deviate from the details of drawing FL-27194.1 require further engineering analysis by a licensed engineer or registered architect
8. See drawing FL-27194.6 for size and design pressure limitations.

Supporting Documents:

1. **Test Report No.** TEL 09453968 — **Test Standard** ASTM E 330-14 — **Testing Laboratory** Testing Evaluation Laboratory — **Signed by** Vivian K. Wright
2. **Drawing No.** No. FL-27194.6 — **Prepared by** RW Building Consultants, Inc. (#9813) — **Signed & Sealed by** Lyndon F. Schmidt, P.E.
3. **Calculations** Anchoring — **Prepared by** RW Building Consultants, Inc. (#9813) — **Signed & Sealed by** Lyndon F. Schmidt, P.E.
4. **Quality Assurance**
   Certificate of Participation issued by National Accreditation and Management Institute, certifying that Qingdao Sea Nova Building Profiles Products Co., LTD, is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.

Digitally signed by Lyndon F Schmidt
Date: 2025.06.19 14:08:27 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by **L. F. Schmidt** on **6-19-25**.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA