



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 E Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

**Eurocraft Industries, Inc.
Series "76 AD" OS French Door
(Impact) (HVHZ)**

for

Florida Product Approval

FL# FL27615

Report No. 6250

Current Florida Building Code

Method: 1 – A (Certificate Method)
Category: Exterior Doors
Sub – Category: Swinging Exterior Door Assemblies


**Product: Series "76 AD" OS French Door
(Impact) (HVHZ)**
Material: Vinyl
Product Dimensions: See installation instructions, ECI009

Prepared For:
Eurocraft Industries, Inc.
7905 NW 77th Ave.
Medley, FL 33166

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 05/22/2019

Contents:

Evaluation Report Pages 1 – 3
Digitally signed by Hermes F Norero
Reason: I am approving this document
Date: 2019.06.10 18:46:23 -04'00'



Hermes F. Norero, P.E.
Florida No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL 27615

Date: 05/12/2019

Report No: 6250

Manufacturer: Eurocraft Industries, Inc.

Product Category: Exterior Doors

Product Sub-Category: Swinging Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(a)

Product Name: Series "76 AD" OS French Door (Impact) (HVHZ)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Eurocraft Industries, Inc.** based on Method 1a of the State of Florida Product Approval, Florida Department of Business & Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **ECI009**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and does not require an impact resistant covering.
5. Site conditions that deviate from the details of drawing **ECI009** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **ECI009** for size and design pressure limitations.



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL 27615

Date: 05/12/2019

Report No: 6250

Quality Assurance:

The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a program audited by and approved by **National Accreditation & Management Institute** (FBC Organization #: **CER1773**).

Performance Standards:

The product described herein has been tested per:

- TAS 201-94
- TAS 202-94
- TAS 203-94

Referenced Data:

1. Product Testing performed by Balckwater Testing, Inc.
(FBC Organization # TST10394)
Report: BT-EUR-18-003, Report Date: 04/23/19
Signed and sealed by Constantin Bortes, FL P.E. 77915
2. Quality Assurance
National Accreditation & Management Institute
(FBC Organization #: **CER1773**)
3. Material Certification
Miami Dade County RER Notice Acceptance
Current NOA for SentryGlas Interlayer by Kuraray America, Inc.

AAMA Fenestration Exterior Profile Certification Program: PVC- AAMA 303,
Profine- Koemmerling-PRO-6, Rigid Polyvinyl Chloride (PVC) Exterior Profiles.

Installation:

Refer to Installation Instructions (**ECI009**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**ECI009**) for design pressures and product sizes.