

Engineering Evaluation Report # 7630-07292026

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

Western Window Systems
2200 E. Riverview Drive
Phoenix, AZ 85034
Tel (877) 268-1300

Product Description:

7630 Series Thermally-Broken, Aluminum, Impact Resistant Fixed Window, LM – FL27960

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with the requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval Document: drawing number PW7630-LM, signed and sealed by A. Lynn Miller, P.E.
2. Test Report No. QAI MED-0054
Fenestration Testing Laboratory
AAMA/WDMA/CSA 101/1.S.2/A440-22
ASTM E1886-19 / ASTM E1996-20 WZ3
AAMA 450-20
3. Anchor Calculations: signed and sealed by A. Lynn Miller, P.E., dated 12/22/2023.

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-24, refer to approval document for glazing details.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded aluminum 6063-T6.
- Units must be installed in accordance with Approval Document, PW7630-LM

