AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 27973
Date: 09/17/2026

Detailed Product Description:
Manufacturer: EXCLUSIVE WOOD DOORS, INC.
Manufacturer Address: 2000 NW 95th AVE., DORAL, FL 33172
Model Name: OUTSWING WOOD ENTRANCE DOOR
Maximum Load: +60PSF, -71.5 PSF (Non-Impact)
Installation Drawings # 18-72F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used _X_ Yes __ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Blackwater Testing Inc.	7/17/2018	BT-EWD-17-004	Constantin Bortes, P.E.
ASTM E331 OR ASTM E547 & TAS 202	Water Penetration	Blackwater Testing Inc.	7/17/2018	BT-EWD-17-004	Constantin Bortes, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Blackwater Testing Inc.	7/17/2018	BT-EWD-17-004	Constantin Bortes, P.E.
AAMA 1304	Forced Entry	Blackwater Testing Inc.	7/17/2018	BT-EWD-17-004	Constantin Bortes, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ
LICENSE
No. 81223
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Sealed: 9/17/2026