



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Product Evaluation Report

of

**Tubelite, Inc.
Aluminum Entrance Doors
(Non-HVHZ) (Non-Impact)**

for

Florida Product Approval

FL# FL28368

Report No. 5973

Current Florida Building Code

Method: 1 – D (Engineering Evaluation)

Category: Exterior Doors

Sub – Category: Swinging Exterior Door Assemblies

Product: Aluminum Entrance Doors

Material: Aluminum

Product Dimensions: Refer to Installation Instructions, TLI001

Prepared for:

Tubelite, Inc.

3056 Walker Ridge Drive N.W.

Walker, Michigan 49544

Prepared by:

Hermes F. Norero, P.E.


Florida Professional Engineer # 73778

Date 9/5/2023

Contents:

Evaluation Report

Pages 1 – 4



Hermes F. Norero, P.E.
Florida No. 73778

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Manufacturer: Tubelite, Inc.

Product Category: Exterior Doors

Product Sub-Category: Swinging Exterior Doors Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: Aluminum Entrance Doors
(Non-HVHZ) (Non-Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Tubelite, Inc.** based on Method 1d of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Current Florida Building Code.

See Installation Instructions **TLI001**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the Current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Current Florida Building Code and **does** require an impact resistant covering.
4. Site conditions that deviate from the details of drawing **TLI001** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **TLI001** for size and design pressure limitations.

Quality Assurance: The manufacturer has demonstrated compliance of products in accordance with the Current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Architectural Testing, Inc., an Intertek Company** (FBC Organization #: QUA1844).

Performance Standards: The product described herein has been tested per:

- ASTM E 283-04(12)
- ASTM E 330-14
- ASTM E 331-00(09)
- ASTM E 2068-00
- AAMA 1304-02

Referenced Data:

1. Product Testing performed by **Architectural Testing, Inc. - York.**
(FBC Organization # TST1558)
Report: B8751.01-109-44 Dated: 05/11/2012
2. Product Testing performed by **Architectural Testing, Inc. - Florida.**
(FBC Organization # TST4311)
C2948.01-450-44 10/26/2012
C2166.01-450-44 10/26/2012
3. Product Testing performed by **Hurricane Test Laboratory, LLC. – Texas.**
(FBC Organization # TST7195)
T584-0301-11-WZ3 08/29/2011
4. Quality Assurance
Architectural Testing, Inc., an Intertek Company
(FBC Organization #: QUA1844)

Installation:

Refer to Installation Instructions (**TLI001**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to installation instructions (**TLI001**) for design pressures dependent on size options.

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. Tubelite Inc. has tested their products to the following test standard edition(s):

1. ASTM E 330-02
2. ASTM E 283-04
3. ASTM E 331-00

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

1. ASTM E 330-14
2. ASTM E 283-04(12)
3. ASTM E 331-00(09)

After review of the above mentioned referenced standards and editions, it has been found that the results and tests carried out meet the requirements for compliance. All referenced standards have been found to be equivalent.