

L. Roberto Lomas P.E.

400 S Palm Ave
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514331A

Manufacturer: MI Windows and Doors, LLC.
650 West Market Street
Gratz, PA 17030

Product Line: 3540 PW CHS Triple Fixed Window 108" x 74", Non-Impact

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03343 revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: C0565.01-109-47 signed and sealed by Michael D. Stremmel, P.E.
Architectural Testing, Inc. York, P.A.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 40.10 psf
Water penetration resistance 7.52psf
3. Anchor calculations, report number 514331-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 40.0 psf
- Unit size: 108" x 74"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03343 revision A.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

