

## PRODUCT APPROVAL EVALUATION REPORT

|                                                                                                                                  |                                                                                                                              |
|----------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|
| <u>Product Manufacturer:</u><br><b>Continental Glass Systems, Inc.</b><br>325 West 74 <sup>th</sup> Place,<br>Hialeah, FL. 33014 | <u>Product Name/Model &amp; Description:</u><br><b>Series 7000 Aluminum Curtain Wall</b><br>- Large and small missile impact |
|----------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|

**Scope:** This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

**Code:** 8<sup>th</sup> Edition Florida Building Code (2023), inclusive of all Supplements effective as of this report date.

**Compliance Method:** 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer


**Product Description:** Product Approval Drawing #AD24-05 & AD24-06, prepared by MCY Engineering, signed and sealed by Yiping Wang, P.E., is an integral part of this Evaluation Report.

### Limitations & Conditions of Use:

- This product has been evaluated for use **Inside and Outside of the HVHZ** (High-Velocity Hurricane Zone)
- Impact Resistance: **Large and Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
  - Maximum allowable wind loads at the related maximum allowable size(s).
  - Other load limitations applicable to the product, if any.
  - Overall dimensions and material/grade of main product components, accessories, etc.
  - Illustrated diagrams of the attachment of the product to the structure
  - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.



March 07th, 2024



## Test Reports:


### Mandatory Tests (Tested in accordance with Florida Building Code Tests Protocols)

| Test Lab                                                       | Report Number                                                       | Test Report Date | Test Standard & Description                                                                                                                                                                                                                                               |
|----------------------------------------------------------------|---------------------------------------------------------------------|------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Blackwater Technical Services, Inc. – West Palm Beach, FL33413 | <i>BT-ESW-21-001, signed and sealed by Michael D Caldwell, P.E.</i> | 01/10/2022       | ASTM E283 (air infiltration)<br>ASTM E331 (water resistance test)<br>TAS 201 (large missile impact test)<br>TAS 201 (small missile impact test)<br>TAS 202 (uniform static test)<br>TAS 203 (cyclic wind pressure loading)<br>ANSI Z97.1<br>ASTM F588 (Forced entry test) |
| Blackwater Technical Services, Inc. – West Palm Beach, FL33413 | <i>BT-CON-23-008, signed and sealed by Michael D Caldwell, P.E.</i> | 02/21/2024       | ASTM E283 (air infiltration)<br>ASTM E331 (water resistance test)<br>TAS 201 (large missile impact test)<br>TAS 202 (uniform static test)<br>TAS 203 (cyclic wind pressure loading)                                                                                       |

### Engineering Analysis:

 The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer's published anchor capacity, anchor Notice of Acceptance by Miami Dade County.



March 07th, 2024