



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 29069

Date: 8/17/2026

Detailed Product Description:

Manufacturer: E.S. WINDOWS, LLC

Manufacturer Address: 3550 NW 49 STREET, MIAMI, FL 33142

Model Name: SERIES WW8701 ALUMINUM WINDOW WALL SYSTEM

Maximum Load: +125 PSF, -125 PSF (Large Missile Impact)

Installation Drawings # 19-06F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes No

Mandatory Tests (Tested in accordance with AAMA 501/101/I.S.2/NAFS/TAS 202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	Blackwater Testing Inc. IFET, Inc.	11/09/2018 10/31/2018 08/10/2026	BT-ESW-18-011 BT-ESW-18-012 TR-IFET-25-0030	Constantin Bortes, PE Constantin Bortes, PE Arshad Viqar, PE
ASTM E331 or ASTM 547 & TAS 202	Water Penetration	Blackwater Testing Inc. IFET, Inc.	11/09/2018 10/31/2018 08/10/2026	BT-ESW-18-011 BT-ESW-18-012 TR-IFET-25-0030	Constantin Bortes, PE Constantin Bortes, PE Arshad Viqar, PE
ASTM E330 & TAS 202	Uniform Static Air Pressure	Blackwater Testing Inc. Blackwater Technical Services, Inc. IFET, Inc.	11/09/2018 10/31/2018 08/20/2026 08/10/2026	BT-ESW-18-011 BT-ESW-18-012 BT-ESW-25-015 TR-IFET-25-0030	Constantin Bortes, PE Constantin Bortes, PE Michael Caldwell, PE Arshad Viqar, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.2 (TAS 201 & 203) ASTM E1886/1996 ANSI Z97.1	Large Missile Impact & Cyclic	Blackwater Testing Inc. Blackwater Technical Services, Inc. IFET, Inc.	11/09/2018 10/31/2018 08/20/2026 08/10/2026	BT-ESW-18-011 BT-ESW-18-012 BT-ESW-25-015 TR-IFET-25-0030	Constantin Bortes, PE Constantin Bortes, PE Michael Caldwell, PE Arshad Viqar, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538



Sealed: 8/20/2026