

Manufacturer: Sky-Frame, Inc.
Langfeldstrasse 111
Frauenfeld, Switzerland CH-8500

Product Line: SF2 Inline Mullion 66, 90, 110

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03377 revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: E2663.01-250-44-R3 signed and sealed by Justin P. McDonald, P.E.
Intertek-ATI, Windham, NH.
TAS 201/ TAS 203
Large Missile Impact Test, Level D, Wind Zone 3.
Cyclic Pressure loading ± 50.0 psf design pressure
TAS 202
Uniform Static Air Pressure, ± 50.0 psf design pressure, 15.04psf water penetration.
3. Mullion analysis with anchor calculations, report number 514370-1A per AAMA 450 options 2 and 3, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to installation instructions
- Maximum mullion height: 144"
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions, up to wind zone 3.
- Mullion material to be extruded Aluminum 6063-T6, with stainless steel reinforcements.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03377, revision A

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

