

PRODUCT APPROVAL EVALUATION REPORT

<u>Product Manufacturer:</u> Continental Glass Systems, LLC. 325 West 74 Place Hialeah, FL 33014	<u>Product Name/Model & Description:</u> Series 3100 Window Wall - L.M.I. & S.M.I. Series 3100 Structural Glazed Window Wall - L.M.I. & S.M.I. Series 3100 Window Wall - S.M.I.
--	---

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: 8th Edition Florida Building Code (2023), inclusive of all Supplements effective as of this report date.

Compliance Method: 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer


Product Description: Product Approval **Drawing #AD19-45, AD23-46, AD24-14** prepared by MCY Engineering, signed and sealed by the Yiping Wang P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **inside and outside the HVHZ** (High Velocity Hurricane Zone)
- Impact Resistance: **Large Missile Impact & Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
 - Maximum allowable wind loads at related maximum allowable size(s).
 - Other load limitations applicable to the product, if any.
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - Illustrated diagrams of the attachment of the product to the structure
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.



May 29, 2024



Test Reports:

Mandatory Tests (Tested in accordance with Florida Building Code Tests Protocols)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Blackwater Testing, Inc. – West Palm Beach, FL	BT-CON-17-003, <i>signed and sealed by Constantin Bortes P.E.</i>	04/06/2017	ASTM E283 (air infiltration) ASTM E331 (water resistance test) TAS 201 (large & small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)
Blackwater Testing, Inc. – West Palm Beach, FL	BT-CON-19-007, <i>signed and sealed by Constantin Bortes P.E.</i>	05/17/2019	ASTM E283 (air infiltration) TAS 201 (Small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)
Fenestration Testing Laboratory, Inc. – Medley, FL	FTL-5246, <i>signed by Carlos S. Rionda, P.E.</i>	06/08/2007	ASTM E283 (air infiltration) TAS 201 (Small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)
Blackwater Testing, Inc. – West Palm Beach, FL	BT-CON-20-015, <i>signed and sealed by Michael D Caldwell P.E.</i>	02/09/2021	ASTM E283 (air infiltration) ASTM E331 (water resistance test) TAS 202 (uniform static test) TAS 201 (large & small missile impact test) TAS 203 (cyclic wind pressure loading)
Blackwater Testing, Inc. – West Palm Beach, FL	BT-CON-16-009 <i>signed and sealed by Michael D Caldwell P.E.</i>	11/28/16	ASTM E283 (air infiltration) TAS 202 (uniform static test) TAS 201 (large & small missile impact test) TAS 203 (cyclic wind pressure loading)
Blackwater Testing, Inc. – West Palm Beach, FL	BT-CON-23 006 <i>signed and sealed by Michael D Caldwell P.E.</i>	02.27.2024	TAS 202 (uniform static test) TAS 201 (large & small missile impact test) TAS 203 (cyclic wind pressure loading) ANSI Z97.1 (impact test). ASTM F588 (forced entry test) ASTM E283 (air infiltration) ASTM E331 (water resistance test)

Engineering Analysis: The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- Rational analysis has been performed per Code requirements and acceptable standards of engineering principles (but not in lieu of standard tests required by the Code). No increase in allowable stress has been used in the evaluation of this product.

May 29, 2024