



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 29244

Date: 07/27/2026

Detailed Product Description:

Manufacturer: SUNSHINE WINDOWS MANUFACTURING INC.

Manufacturer Address: 1785 W 33 PLACE, HIALEAH, FL 33012

Model Name: SERIES "2000" ALUMINUM SINGLE HUNG WINDOW

Maximum Load: +75 PSF, -112.5 PSF (Non-Impact)

Installation Drawings # 19-17F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used <u> X </u> Yes <u> </u> No					
Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)					
Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratory, Inc	8/27/2007	FTL-5124	Carlos S. Rionda, P.E
			9/7/2018	FTL-10290	Idalmis Ortega, P.E.
			10/2/2007	FTL-5397	Michael Wenzel, P.E.
ASTM E331 OR ASTM E547 & TAS 202	Water Penetration	Fenestration Testing Laboratory, Inc	8/27/2007	FTL-5124	Carlos S. Rionda, P.E
			9/7/2018	FTL-10290	Idalmis Ortega, P.E.
			10/2/2007	FTL-5397	Michael Wenzel, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Laboratory, Inc	8/27/2007	FTL-5124	Carlos S. Rionda, P.E
			9/7/2018	FTL-10290	Idalmis Ortega, P.E.
			10/2/2007	FTL-5397	Michael Wenzel, P.E.
ASTM F588	Forced Entry Test	Fenestration Testing Laboratory, Inc	8/27/2007	FTL-5124	Carlos S. Rionda, P.E
			9/7/2018	FTL-10290	Idalmis Ortega, P.E.
			10/2/2007	FTL-5397	Michael Wenzel, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 7/27/2026