BUILDING DROPS
A Perfect Solution in Every Drop!
Certificate of Authorization: 29578

398 East Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

Air-Lux Technik AG
Series 173 Window Wall
(WZ3) (Impact)

for

Florida Product Approval

FL# FL29500

Report No. 7334

Current Florida Building Code

Method:	**1 – D (Engineering Evaluation)**
Category:	**Panel Walls**
Sub – Category:	**Storefront**
Product:	**Series 173 Window Wall**
Materials:	**Aluminum**
Product Dimensions:	**See Installation Instructions, ALT004**

Prepared for:
Air-Lux Technik AG
Breitschachenstrasse 52
9032 Engelburh/SG, Switzerland

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 10/30/2020



Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F Norero
Reason: I am approving this document
Date: 2020.12.20 22:56:32 -05'00'

Hermes F. Norero, P.E.
Florida No. 73778

Manufacturer:	**Air-Lux Technik AG**
Product Category:	Panel Walls
Product Sub-Category:	Storefront
Compliance Method:	State Product Approval Method (1)(d)
Product Name:	**Series 173 Window Wall (WZ3) (Impact)**

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Air-Lux Technik AG** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **ALT004**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does not require** an impact resistant covering in Wind Zone 3 or less.
4. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering in Wind Zone 4.
5. Site conditions that deviate from the details of installation instructions **ALT004** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **ALT004** for size and design pressure limitations.

Quality Assurance: The manufacturer has demonstrated compliance of manufacture of products in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation and Management Institute, Inc.** (FBC Organization # QUA1789).

Performance Standards: The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-11
- ASTM E1886-13a
- ASTM E1996-17
- TAS 201-94
- TAS 202-94
- TAS 203-94

Referenced Data:

1. Product Testing performed by **UL, LLC.**
   (FBC Organization #: TST9628)
   Report #: SV31047-20180206, Report Date: 04/05/19
   Report #: SV31047-20181203, Report Date: 03/01/19
   Reports signed and sealed by Alexis Spyrou, FL P.E. No. 68101

2. Quality Assurance Agency
   National Accreditation & Management Institute
   (FBC Organization #QUA1789)

Installation:

Refer to Installation Instructions (**ALT004**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**ALT004**) for design pressures based on size, configuration, and glass types.

Equivalence of Test Standards:

Various test standards have been evaluated for differences in the test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. Air-Lux Technik AG has tested their products to the following test standard edition(s):

1) ASTM E1886-05
2) ASTM E1996-09

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

1) ASTM E1886-13a
2) ASTM E1996-17

After review of the above mentioned referenced standards and editions, it has been found that the results and tests carried out meet the requirements for compliance. All referenced standards have been found to be equivalent.