

Manufacturer:

Winco Window Co.
6200 Maple Ave.
St. Louis, MO 63130

Product Line:

3250 Fixed Window – (Impact)

Product Description:

Architectural Aluminum Window. The frame is made from 6063-T6 Aluminum. Insulated Glass, outboard to inboard, consisting of (1/4" HS) - (7/16" Air) - (3/16 HS-0.090 Saflex-3/16" HS)

Compliance:


The above product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.006. The product Herein complies with the Florida Building Code 8th Edition (2023).

Documentation:

1. Report No: SV30610-20181116-R3
UL, LLC
Northbrook, IL
2. AAMA CPD# 18133 & 18134
3. Anchor Calculations prepared, signed, and sealed by Wayne Helmila, PE
4. Drawings titled 3250 FX Impact prepared, signed, and sealed by Wayne Helmila, PE

Codes & Limitations:

- | | |
|---|------------------------------|
| 1. ASTM E330-14 | +/- 90 psf |
| 2. ASTM E1886-13a | +/- 90 psf |
| 3. ASTM E1996-14a | 9# @ 50ft/s |
| 4. TAS 201-94 | 9# @ 50ft/s |
| 5. TAS 202-94 | +/- 90 psf |
| 6. TAS 203-94 | +/- cycling |
| 7. ASTM E1300-12 | |
| 8. AAMA/WDMA/CSA 101/I.S.2/A440-11 | AW-PG90-1524x2515 (60x99)-FW |
| 9. Max. window size | 60" x 99" |
| 10. Max. design pressure | +/- 90 psf |
| 11. The product <u>is approved</u> for large missile impact protection. | |
| 12. The product <u>is approved</u> for use in HVHZ zones. | |
| 13. Units must be installed in accordance with manufacturer instructions. | |



03/21/2024
COA: 9090

Certificate of Independence:

I certify that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Additionally, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Wayne K Helmila

Digitally signed by Wayne K Helmila
DN: CN=Wayne K Helmila,
dnQualifier=A01410C000018CDB8F4AFB001A652B,
O=Wisconsin, C=US
Date: 2024.03.21 14:45:03-05'00'

RICE
ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com

Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092