



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 29712

Date: 07/20/2023

Detailed Product Description:

Manufacturer: HOPE'S WINDOWS, INC.

Manufacturer Address: 84 HOPKINS AVE, P.O. BOX 580 JAMESTOWN, NEW YORK 14701

Model Name: JAMESTOWN 175 CENTER PIVOT INSWING DOOR

Maximum Load: +60 PSF, -60 PSF (Large Missile Impact)

Installation Drawings # 19-34F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Element Materials Technology	3/25/2019 9/4/2019	ESP030347P-2406 ESP030347P-2406.1	Jason R. Steen, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Element Materials Technology	3/25/2019 9/4/2019	ESP030347P-2406 ESP030347P-2406.1	Jason R. Steen, P.E.
ASTM E331 OR ASTM E547 & TAS 202	Water Penetration	Element Materials Technology	3/25/2019 9/4/2019	ESP030347P-2406 ESP030347P-2406.1	Jason R. Steen, P.E.
AAMA 1304	Forced Entry Test	Element Materials Technology	3/25/2019 9/4/2019	ESP030347P-2406 ESP030347P-2406.1	Jason R. Steen, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Element Materials Technology	3/25/2019 9/4/2019	ESP030347P-2406 ESP030347P-2406.1	Jason R. Steen, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538



Sealed: 8/9/2023