



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 29716

Date: 09/01/2020

Detailed Product Description:

Manufacturer: WESTERN WINDOW SYSTEMS

Manufacturer Address: 2200 E RIVERVIEW DRIVE PHOENIX, ARIZONA 85034

Model Name: SERIES 7980 ALUMINUM PIVOT DOOR

Maximum Load: +50.1 PSF, -50.1 PSF (Non-Impact)

Installation Drawings #19-50F

This product does not comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used Yes X No

Mandatory Tests (Tested in accordance with AAMA/WDMA/CSA101/IS2/A440)

Test	Description	Test Location	Test Report Date	Test Report #
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratories, Inc	5/22/2018	T18-026
ASTM E330	Uniform Static Air Press.	Fenestration Testing Laboratories, Inc	5/23/2018	T18-027
AAMA 1304	Forced Entry	Fenestration Testing Laboratories, Inc	5/24/2018	T18-028

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 10/2/2020