



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 29882

Date: 09/01/2020

Detailed Product Description:

Manufacturer: WESTERN WINDOW SYSTEMS

Manufacturer Address: 2200 E RIVERVIEW DRIVE PHOENIX, ARIZONA 85034

Model Name: SERIES 7900 THERMAL ALUMINUM OUTSWING DOOR

Maximum Load: +50 PSF, -50 PSF (Non-Impact)

Installation Drawings #19-59F

This product does <u>not</u> comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.				
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.				
Comparative analysis used <u> </u> Yes <u> X </u> No				
Mandatory Tests (Tested in accordance with AAMA/WDMA/CSA101/IS2/A440)				
Test	Description	Test Location	Test Report Date	Test Report #
ASTM E283	Air Infiltration Leakage	Intertek Fenestration Testing Laboratory, Inc.	6/25/2019	I9710.01-301-18
			6/28/2018	T18-010
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Intertek Fenestration Testing Laboratory, Inc.	6/25/2019	I9710.01-301-18
			6/28/2018	T18-010
ASTM E330 & TAS 202	Uniform Static Air Press.	Intertek Fenestration Testing Laboratory, Inc.	6/25/2019	I9710.01-301-18
			6/28/2018	T18-010
AAMA 1304	Forced Entry	Intertek Fenestration Testing Laboratory, Inc.	6/25/2019	I9710.01-301-18
			6/28/2018	T18-010
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.				
Evaluation Report Engineer:				
Jalal Farooq Al-Farooq Corporation		PE # 81223 EB # 3538 Sealed: 10/2/2020		