

## AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

## PRODUCT APPROVAL EVALUATION **RULE CHAPTER #61G20-3 • METHOD 1 OPTION D**

FL 30035 Date: 8/2/19

**Detailed Product Description:** 

Manufacturer: ENVIRALUM INDUSTRIES, INC

Manufacturer Address: 5100 NW 72ND AVENUE, BLDG C. MIAMI, FL 33166

Model Name: SERIES ENV-350 OUTSWING CASEMENT WINDOW

Maximum Frame Width: 65-1/2" Maximum Frame Height: 121-3/4"

Maximum Load: +120 PSF, -120 PSF (Large Missile Impact)

Installation Drawings # 19-70F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

Camananativa analysis was d	V	V NI-
Comparative analysis used	YAS	X No
comparative analysis asea	1 0 3	/\ 1 <b>1</b> 0

Mandatory Tests (Tested in accordance with AAMA 101/1.5.2/NAF5/TA5-202)							
TEST	DESCRIPTION	TEST LOCATION	REPORT	TEST	Test		
			DATE	REPORT #	Sealed by		
ASTM E283	Air Infiltration	Blackwater Testing, Inc	06/21/19	BT-ENI-19-001	Constantin Bortes, P. E.		
	Leakage						
ASTM E331	Water	Blackwater Testing, Inc	06/21/19	BT-ENI-19-001	Constantin Bortes, P. E		
OR ASTM 547	Penetration						
& TAS 202							
ASTM E330	Uniform Static Air	Blackwater Testing, Inc	06/21/19	BT-ENI-19-001	Constantin Bortes, P. E.		
& TAS 202	Press.						
ASTM F588	Forced Entry Test	Blackwater Testing, Inc	06/21/19	BT-ENI-19-001	Constantin Bortes, P. E.		

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT	TEST	Test
			DATE	REPORT #	Sealed by
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Blackwater Testing, Inc	06/21/19	BT-ENI-19-001	Constantin Bortes, P. E
ASTM E1886/1996					

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2017 Florida Building Code.

**Evaluation Report Engineer:** 

Sealed 08/05/2019

Javad Ahmad PE # 70592 Al-Farooq Corporation EB # 3538