

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

GARAGE DOOR EVALUATION REPORT

Garage Door No.:	IBC-1710-110-11		Test Date:	9/5/2018		Project No.:	18-105	
Design Pressures:	+17.3 psf, -20.1 psf		Report Date:	10/14/2020		Model #	1700	
Test Pressures:	+26 psf, -30.2 psf		Test Location:	Entrematic, Winston-Salem, NC				
ASCE 7-16 Criteria:	Up to 5 Feet of Door Width in Zone 5; Roof Slope ≤ 10°; Enclosed Building							
	Exp. B, 30' MRH	Exp. C, 15' MRH	Exp. C, 25' MRH	Exp. D, 15' MRH	Exp. D, 25' MRH			
	142 mph	129 mph	123 mph	117 mph	112 mph			

Reference Test Report and Drawing:

- Structural Solutions, P.A.* Garage Door Static Pressure Test Report for IBC-1710-110-11 dated 10/14/2020
- Entrematic Drawing number IBC-1710-110-11 dated 7/29/2019

Description of Test Specimen:

10'-2"x8'-0" Model 1700, 27 ga steel garage door as shown in drawing IBC-1710-110-11.

Test Standards and Report Conclusion:

The above referenced Test Report states the following:

- The tests were conducted in accordance with ASTM E330-14 and DASMA 108-12.
- The test was witnessed and certified by Thomas L. Shelmerdine, PE (FL PE# 48579)
- The test facility at Entrematic is accredited by the American Association for Laboratory Accreditation, Certificate #2595.01.


Summary:

The 10'-2"x8'-0" Model 1700 as described on drawing IBC-1710-110-11 meets or exceeds the testing criteria as described above. By comparison to the construction of the 10'-2"x8'-0" Model 1700, the following doors also meet or exceed the above testing criteria, when constructed in accordance with drawing IBC-1710-110-11:

- 10'-2" x 8' Amarr 2732 doors, which is an alternate model number
- Model 1700 and Amarr 2732 doors with widths up to 10'-2" and heights up to 24'-0"
- 3 windows may be installed in 1 section (21 3/8" x 3 1/4" x 0.080" plexiglas, or 21 5/8" x 9 5/8" x 1/8" tempered glass)

To the best of my knowledge, the above garage door conforms to the requirements of the Florida Building Code 7th Edition (2020).

Submitted By:



STRUCTURAL SOLUTIONS, P.A.* (*Florida: dba Structural Solutions of North Carolina, Inc., Firm #29412)

Thomas L. Shelmerdine, PE (NC PE #14654; Florida PE #0048579)

5921-G West Friendly Avenue ■ Greensboro, North Carolina 27410 ■ (336) 856-2686 ■ www.sspa.biz ■ NC Firm #C-1096