



EVALUATION REPORT

FLORIDA BUILDING CODE, 8TH EDITION (2023)

Manufacturer: DREXEL METALS INC.
1234 Gardiner Lane
Louisville, KY 40213
(502) 716-7143
www.drexmet.com

Issued October 1, 2023

Manufacturing: Port St. Lucie, FL

Quality Assurance: Architectural Testing, Inc., an Intertek Company (QUA1844)


SCOPE

Category: Roofing
Subcategory: Roofing Accessories that are an integral part of the roofing system
Code Edition: Florida Building Code, 8th Edition (2023) High-Velocity Hurricane Zones (HVHZ)
Code Sections: 1518.8.1
Properties: Wind Resistance


PRODUCT DESCRIPTION

26GA RIDGE TILE CHANNEL

Dimensions: 10-ft length; Available in 3, 4, 5, 6, or 8-inch heights
Description: Steel ridge anchor for use with clay and concrete roof tiles
Material: Min. 26 ga. ASTM A 653 G90; F_y = min. 33 ksi; Shall conform with FBC Section 1517.6



Profile #1



Profile #2




APPLICATION METHOD

The component and installation shall comply with one of the following:

- 1) RAS 118, Detail 3
- 2) RAS 119, Detail 3
- 3) RAS 120, Detail 3

Refer to manufacturer's installation instructions as a supplemental guide for attachment.




LIMITATIONS

1. Installation of the evaluated products shall comply with this report, the FBC and the manufacturer's published application instructions. Where discrepancies exist between these sources, the more restrictive and FBC compliant installation detail shall prevail.
2. Design of a support system is outside the scope of this report.
3. All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.

COMPLIANCE STATEMENT

The products evaluated herein by Zachary R. Priest, P.E. have demonstrated compliance with the Florida Building Code, 8th Edition (2023) including High-Velocity Hurricane Zones (HVHZ) as evidenced in the referenced documents submitted by the named manufacturer.



This item has been
digitally signed and
sealed by Zachary R.
Priest, PE, on 10/1/2023.

Printed copies of this
document are not
considered signed and
sealed and the signature
must be verified on any
electronic copies.


Digitally signed by Zachary R. Priest
CREEK Technical Services, LLC

2023.10.01
14:34:40
-04'00'

Zachary R. Priest, P.E.
Florida Registration No. 74021
Organization No. ANE9641

CERTIFICATION OF INDEPENDENCE

CREEK Technical Services, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

CREEK Technical Services, LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT