

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 30270

Date: 9/19/2023

Detailed Product Description:


Manufacturer: RIVIERA BRONZE

Manufacturer Address: 1895 N. VENTURA AVE. VENTURA, CA. 93001

Model Name: STEEL OUTSWING ENTRANCE DOOR

Maximum Load: +54.0 PSF, -72.0 PSF (Non-Impact)

Installation Drawings # 19-64F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used ☐ Yes ☒ No					
Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Intertek	07/11/2019	J5877.01-301-18 J5878.01-301-18	Tyler Westerling, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Intertek	07/11/2019	J5877.01-301-18 J5878.01-301-18	Tyler Westerling, P.E.
ASTM E330 & TAS 202	Uniform Static Air Pressure	Intertek	07/11/2019	J5877.01-301-18 J5878.01-301-18	Tyler Westerling, P.E.
AAMA 1304	Forced Entry	Intertek	07/11/2019	J5877.01-301-18 J5878.01-301-18	Tyler Westerling, P.E.
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.					
Evaluation Report Engineer:					
Jalal Farooq Al-Farooq Corporation		PE # 81223 EB # 3538		 Sealed: 9/20/2023	