

Product Evaluation Report**Report No.: FL-30446.2****Date: September 23, 2019**

Product Category	Sub Category	Manufacturer	Product Name
Windows	Fixed	Window Technology, Inc. 201 Industrial Drive Monett, MO 65708 (417) 235-7821	Model 325 Aluminum Fixed Window w/ Nailing Fin "Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Window Technology, Inc., Inc. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.


RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 6th Edition (2017) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require any impact resistant covering. This product meets missile level "D" and excludes Wind Zone 4 as defined in ASTM E1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x brick masonry construction.
5. Site conditions that deviate from the details of drawing FL-30446.2 require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-30446.2 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|---|---|--|
| 1. Test Report No.
CCL 19-096 | Test Standard
ASTM E1886-13a/E1996-14a
AAMA/WDMA/CSA 101/I.S.2/A440-11 | Testing Laboratory
Construction Consulting Laboratory | Signed by
Wesley Wilson |
| 2. Miami-Dade NOA No.
19-0305.02 | Materials Testing
Trosofil PVB Interlayer (Kuraray America, Inc.) | | |
| 3. Drawing No.
No. FL-30446.2 | Prepared by
RW Building Consultants, Inc. (CA #9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 4. Calculations
Anchoring | Prepared by
RW Building Consultants, Inc. (CA #9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 5. Quality Assurance
Certificate of Participation issued by Keystone Certifications, Inc., certifying that Window Technology, Inc., Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53 | | | |



Lyndon F. Schmidt, P.E.
FL PE No. 43409
9/23/2019