

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: MULTIVI LIFT & SLIDE GLAZED WOOD DOOR

MANUFACTURER: MULTIVI S.A. DE C.V.
CARRIL DE SAN CRISTOBAL, 134-A
PARK INDUSTRIAL CHACHAPA
AMAZOC DE MOTA, PUEBLA, MEXICO 72990

To all concerned,

The Multivi Lift & Slide Glazed Wood Door, manufactured by Multivi S.A. De C.V, is a glazed wood sliding glass door with aluminum cladding, set in a wood frame with aluminum tracks. The wood part of the door is made from American Oak. The door has been tested per TAS 201, 202, and 203 by Intertek B&C, with results shown in test report I7686.01-450-18.

Technical Documentation:

1. Drawing "MLS-LMIHZ", dated 10/18/24 (Rev. 2), signed and sealed by Scott Wolters, PE.
2. Test Report listed above by Intertek B&C, signed and sealed by Vinu Abraham, PE.
3. Supplemental calculations to support "MLS-LMIHZ", signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 8th Edition (2023) Florida Building Code generally, and chapters 10, 11, 16, 23, and 24 specifically, including the HVHZ provisions.

Limitations: This door is approved for use inside and outside of the HVHZ. It is large and small impact resistant. Shutters are not required.

<u>Overall Dimensions:</u>	Max Frame Height:	106 13/16"
	Max Frame Width:	117 3/8"
	Max Panel Height:	104 1/16"
	Max Panel Width:	59 7/16"
	Max Design Pressure:	+/- 55 psf

Glazing:

9/16" Monolithic Laminated
1/4" Heat Strengthened
0.090" Sentryglas Interlayer*
1/4" Heat Strengthened

Max DLO = 53 5/16" x 95 3/16"

* The 0.090" Sentryglas Interlayer is manufactured by Kuraray America, per NOA# 23-0717.30.

Locking Hardware:

Manufacturer's standard 2-pt. Lock at Lock Jamb.

Drainage System:

Where resistance to water infiltration is required, the drainage system shown on sheets 7 & 8 of drawing MLS-LMIHZ must be installed. The drainage system is not a part of this approval, and must be approved by the Authorities Having Jurisdiction (AHJ)

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
OCT 18 2024

