L. Roberto Lomas P.E.
208 7th Ave.
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514554B

Manufacturer: Lanai Doors
941 North Elm Street, Suite C
Orange, CA 92867

Product Line: Series E3 Inswing Aluminum Bi-Fold Door, Impact Non-HVHZ

Compliance:
The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:
1. Approval document: drawing number 08-03505, Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: A0896.02-301-18 signed and sealed by Tyler Westerling P.E.
   Architectural Testing, Fresno, CA
   TAS 201/TAS 203 Large Missile Impact Test, Level D, Wind Zone 4
   Cyclic Pressure loading ±90.0psf design pressure (Standard Threshold)
   ±70.0psf design pressure (Flush Guide and Low Rise Threshold)
   TAS 202 Uniform Static Air Pressure, +80.0/-100.0psf design pressure. (Standard Threshold)
   ±70.0psf design pressure (Flush Guide Threshold)
3. Anchor calculations, report number 514554-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.
4. Comparative analysis, report number 514554-2, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:
- Design pressure: Refer to installation drawing.
- Panel size: 36” x 96”
- Units must be glazed per ASTM E1300, according to glazing details in approval drawing.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T5.

Installation:
Units must be installed in accordance with manufacturer’s installation instructions and approval document 08-03505, Revision B.
When the product specified herein is installed within 3000 ft. of a saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 1.

Certification of Independence:
Please note that I don’t have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don’t have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E.
FL No.: 62514
10/14/2026