

Product Evaluation Report

Report No. ACE-PER-1229, Rev. 0 | Project No. ACE-2025-127 | 8/4/26 | Page 1 of 3

Product Manufacturer

Renaissance Windows and Doors
13340 International Parkway
Jacksonville, FL 32218

Product Name, Model and/or Description

Series 8500 Vinyl Single Hung Window - Single
Series 8500 Vinyl Single Hung Window - Twin
Series 8500 Vinyl Single Hung Window – Triple
Series 9700 Vinyl Single Hung Window

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Method: 61G20-3.005(1)(A) – Certification Mark or Listing

Installation Drawing No., Product Name, Model and/or Designation; Test Report No.:

- Series 8500 Vinyl Single Hung Window – Single
 - National Certified Testing Laboratory Report No. NCTL-210-4105-02, dated 3/1/18, Series 8500 Vinyl Tilt Single Hung Window tested to AAMA/WDMA/CSA 101/I.S.2/A440-08 and 11, Class R-PG35, 53.125" x 63" (Nominal 52 x 63).
 - Drawing No. RWD0015, Rev. A, dated 8/4/26, signed and sealed by Robert. J. Amoruso, Renaissance Windows and Doors, Series 8500 Single Hung Window, Installation Anchorage Details.
- Series 8500 Vinyl Single Hung Window – Twin
 - National Certified Testing Laboratory Report No. NCTL-210-4105-04, dated 3/16/18, Series 8500 Vinyl Twin Single Hung Window tested to AAMA/WDMA/CSA 101/I.S.2/A440-08 and 11, Class R-PG35, 96.5" x 72" (Nominal 97 x 72).
 - Drawing No. RWD0018, Rev. A, dated 8/4/26, signed and sealed by Robert. J. Amoruso, Renaissance Windows and Doors, Series 8500 Single Hung Window, Installation Anchorage Details.
- Series 8500 Vinyl Single Hung Window – Triple
 - National Certified Testing Laboratory Report No. NCTL-210-4105-02A, dated 3/16/18, Series 8500 Vinyl Triple Single Hung Window tested to AAMA/WDMA/CSA 101/I.S.2/A440-08 and 11, Class R-PG40, 108.75" x 72" (Nominal 109 x 72).
 - Gateway size testing based on National Certified Testing Laboratory Report No. NCTL-210-4105-02, dated 3/1/18, Series 8500 Vinyl Tilt Single Hung Window tested to AAMA/WDMA/CSA 101/I.S.2/A440-08 and 11.
 - Drawing No. RWD0018, Rev. A, dated 8/4/26, signed and sealed by Robert. J. Amoruso, Renaissance Windows and Doors, Series 8500 Single Hung Window, Installation Anchorage Details.
- Series 9700 Vinyl Single Hung Window
 - National Certified Testing Laboratory Report No. NCTL-210-4128-02, dated 12/17/18, Series 9700 Vinyl Single Hung Window tested to AAMA/WDMA/CSA 101/I.S.2/A440-08 and 11, ASTM E1886-05 and ASTM E1996-05/09, Class R-PG50, 63" x 44"
 - Drawing No. RWD0023, Rev. A, dated 8/4/26, signed and sealed by Robert. J. Amoruso, Renaissance Windows and Doors, Series 9700 Vinyl Single Hung Window, Installation Anchorage Details.

Engineering Analysis & Evaluation:

- Series 8500 Vinyl Single Hung Window – Single
 - Anchorage engineering (ACE-CALC-2542) in accordance with the current edition of the Florida Building Code for Series 8500 Vinyl Fixed Window signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752.

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

Product Evaluation Report

Report No. ACE-PER-1229, Rev. 0 | Project No. ACE-2025-127 | 8/4/26 | Page 2 of 3

- Series 8500 Vinyl Single Hung Window – Twin & Triple
 - Anchorage to structural substrate has been verified by calculation (ACE-CALC-2554) prepared by Robert J. Amoruso, P.E. in accordance with the current edition of the Florida Building Code.
- Series 9700 Vinyl Single Hung Window
 - Anchorage to structural substrate has been verified by calculation (ACE-CALC-2656) prepared by Robert J. Amoruso, P.E. in accordance with the current edition of the Florida Building Code.

Performance Standards (used in testing):

- AAMA/WDMA/CSA 101/I.S. 2/A440-08
- AAMA/WDMA/CSA 101/I.S. 2/A440-11
- ASTM E1886-05
- ASTM E1996-05/09

Limitations & Conditions of Use:

- The following products have NOT been evaluated for use inside the High Velocity Hurricane Zone (HVHZ).
 - Series 8500 Vinyl Single Hung Window - Single
 - Series 8500 Vinyl Single Hung Window - Twin
 - Series 8500 Vinyl Single Hung Window – Triple
 - Series 9700 Vinyl Single Hung Window
 -
- The following products will require an approved impact protective system when used in windborne debris regions.
 - Series 8500 Vinyl Single Hung Window - Single
 - Series 8500 Vinyl Single Hung Window - Twin
 - Series 8500 Vinyl Single Hung Window – Triple
- The following product will NOT require an approved impact protective system when used in windborne debris regions.
 - Series 9700 Vinyl Single Hung Window
- Refer to Product Installation Instructions noted above for:
 - Maximum allowable wind loads at related maximum allowable size(s).
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - Illustrated diagrams of the attachment of the product to substrate structure.
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.
- Site wind pressures shall be determined by a licensed professional engineer in accordance with the current edition of the Florida Building Code (and/or ASCE 7 as referenced in the current edition of the Florida Building Code) for components and cladding based on allowable stress design.
- Site conditions not covered in this product evaluation document are subject to additional engineering analysis by a licensed professional engineer or registered architect as required by the authority having jurisdiction.
- Adequacy of the existing structural substrates as a main wind force resisting system capable of withstanding and transferring applied product loads to the foundation is the responsibility of the licensed professional engineer or registered architect acting as the design professional of record for the project of installation.


Product Evaluation Report

Report No. ACE-PER-1229, Rev. 0 | Project No. ACE-2025-127 | 8/4/26 | Page 3 of 3

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso
Date:
2026.08.15
15:28:00 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com