

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 31179

Date: 09/22/2026

Detailed Product Description:


Manufacturer: SUNSHINE WINDOWS MANUFACTURING, INC.

Manufacturer Address: 1785 W 33 PLACE, HIALEAH, FL 33012

Model Name: SERIES 2011 ALUMINUM FIXED WINDOW

Maximum Load: +110 PSF, -110 PSF (Large Missile Impact)

Installation Drawings # 19-120F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used ☒ Yes ☐ No					
Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)					
Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratory, Inc.	10/30/2014 6/20/2019	FTL-7853 FTL-10674	Idalmis Ortega, P.E.
ASTM E331 or ASTM 547 & TAS 202	Water Penetration	Fenestration Testing Laboratory, Inc.	10/30/2014 6/20/2019	FTL-7853 FTL-10674	Idalmis Ortega, P.E.
ASTM E330 & TAS 202	Uniform Static Air Pressure	Fenestration Testing Laboratory, Inc.	10/30/2014 6/20/2019 10/10/2019	FTL-7853 FTL-10674 FTL-10875	Idalmis Ortega, P.E.
ASTM F588	Forced Entry	Fenestration Testing Laboratory, Inc.	10/30/2014	FTL-7853	Idalmis Ortega, P.E.
Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)					
Test	Description	Test Location	Test Report Date	Test Report#	Test Sealed By
FBC 1626.2 TAS 201 & 203 ANSI Z97.1	Large Missile Impact & Cyclic	Fenestration Testing Laboratory, Inc.	10/30/2014 6/20/2019 10/10/2019	FTL-7853 FTL-10674 FTL-10875	Idalmis Ortega, P.E.
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.					
Evaluation Report Engineer:					
Jalal Farooq Al-Farooq Corporation					
PE # 81223 EB # 3538			Sealed: 9/22/2026		