

Engineering Evaluation Report #3100-042523.1

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

CGI Windows and Doors
3780 W 104th St.
Hialeah, FL 33018

Product Description:

Aluminum Tube Mullions & Clips, LMI, 3100 Series, FL-31232

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval Document: drawing number MULLFBC-1, signed and sealed by A. Lynn Miller, P.E.
2. Mullion Analysis, prepared, signed and sealed by A. Lynn Miller, P.E., Dated 4/16/21

Limitations and Conditions of use:

- This product is impact resistant and does not require impact protection in wind borne debris regions, up to wind zone 3.
- Mullion and clip material to be extruded aluminum 6063-T6.
- Units attached to mullion must have their own separate approval.
- Units must be installed in accordance with Approval Document, MULLFBC-1.



A. Lynn Miller, P.E.
P.E. # 58705