



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Product Evaluation Report

of

**Kawneer Company, Inc.
1600 System 1 Curtain Wall
(HVHZ) (Missile Level E)**

for

Florida Product Approval

FL# FL32409

Report No. 8900

Current Florida Building Code

Method:	1 – D (Engineering Evaluation)
Category:	Panel Walls
Sub – Category:	Curtain Walls
Product:	1600 System 1 Curtain Wall (HVHZ)(Missile Level E)
Materials:	Aluminum
Product Dimensions:	See Installation Instructions, KAW027

Prepared for:

**Kawneer Company, Inc.
555 Guthridge Courts
Norcross, GA 30092**


Prepared by:

Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 10/05/2023

Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2023.10.19 12:17:33 -04'00'



Hermes F. Norero, P.E.
Florida No. 73778

Manufacturer: Kawneer Company, Inc.

Product Category: Panel Walls

Product Sub-Category: Curtain Walls

Compliance Method: State Product Approval Method (1)(d)

Product Name: **1600 System 1 Curtain Walls
(HVHZ) (Missile Level E)**

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Kawneer Company, Inc.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **KAW027**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **including** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does not require** an impact resistant covering.
4. Site conditions that deviate from the details of installation instructions **KAW027** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **KAW027** for size and design pressure limitations.

Quality Assurance:

The manufacturer has demonstrated compliance of manufacture of products in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Architectural Testing, Inc., an Intertek Company.** (FBC Organization # QUA1844)

Performance Standards:

The product described herein has been tested per:

- AAMA 501-15
- ASTM E283-04(12)
- ASTM E330-14
- ASTM E331-00(16)
- ASTM E1886-13a
- ASTM E1996-17
- TAS 201-94
- TAS 202-94
- TAS 203-94

Referenced Data:

1. Product Testing performed by **Architectural Testing, Inc. (an Intertek company) - Lithia Springs, GA / Atlanta**
(FBC Organization # TST3892)
Report #: I7021.01-550-18, Report Date: 12/14/18
Report #: I7021.02-550-18, Report Date: 12/14/18
Report #: I7021.03-550-18, Report Date: 12/14/18
TAS Reports Signed and Sealed by Vinu J. Abraham, FL P.E. No. 53820
2. Material Certification
Miami-Dade County Notice of Acceptance
Kuraray America, Inc.
SentryGlas Interlayer
3. Quality Assurance
Architectural Testing, Inc., an Intertek Company.
(FBC Organization #: QUA1844)



FL#: **FL32409**
Date: 10/05/2023
Report No: 8900

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Installation:

Refer to Installation Instructions (**KAW027**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**KAW027**) for design pressures based on size, configuration, and glass types.