

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: DITEC DS20H SERIES AUTOMATIC SLIDING DOOR SYSTEM
(FULL BREAK-OUT)

MANUFACTURER: ENTREMATIC USA
1900 AIRPORT ROAD
MONROE, NC 28110

To all concerned,

The Ditec DS20H Series Automatic Sliding Door System, manufactured by Entrematic USA, is a multi-panel glazed aluminum automatic sliding door set in an aluminum frame. The door has been tested per TAS 201, 202, and 203 by Intertek B&C, with results shown in test reports J5787.16-550-18-R0 thru J5787.30-550-18-R0.

Technical Documentation:

1. Drawing "EM-DS20H-D-FBO-HVHZ" dated 6/10/22 (Rev. 1), signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Intertek B&C, signed and sealed by Vinu Abraham, PE.
3. Supplemental Calculations to support EM-DS20H-D-FBO-HVHZ, signed & sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 7th Edition (2020) Florida Building Code generally, and chapters 10, 11, 16, 23, and 24 specifically, including the HVHZ provisions.

Limitations: This door is approved for use inside and outside of the HVHZ. Glass Type 1 is Large and Small Missile Impact Resistant. Glass Type 2 is not impact resistant, and shutters are required in windborne debris regions.

<u>Overall Dimensions:</u>	Maximum Frame Height:	104"
	Maximum Frame Width:	192" (Bi-Parting) or 102" (Single Slide)
	Maximum Panel Width:	Varies - see charts on sheets 6 & 8.
	Maximum Design Pressure:	+/- 70 psf (Bi-Parting)
		+/- 75 psf (Single Slide)

This door system is not tested or rated for water infiltration resistance. It is intended for use only in locations where water infiltration resistance is not required, or where it is protected by an overhang meeting the requirements of FBC Section 1709.5.1.

Glass: Type 1: 9/16" Laminated (LMI – Level D)
1/4" Heat Strengthened
0.090" SentryGlas Interlayer (NOA# 20-0915.19)
1/4" Heat Strengthened

Type 2: 1/4" Tempered (Non-Impact)

Locks: Manufacturer's Standard 3 Pt Lock (Single Slide) or 4 Pt. Lock (Bi-Part)
Or
Adams-Rite 8600 Series CVR Panic

Please see Bill of Materials on Sheets 15-17 for a complete list of door hardware requirements.
If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
JUN 10 2022

